



EXAMPLE:
SEE
GENERAL
NOTES.

1
101 8'-0" CONCRETE BASEMENT
WALL DETAIL

- NOTES:**
- CONC. STRENGTH = 3000psi MIN. @ 28 DAYS
 - REINFORCEMENT = GR 40 (fy=40,000 psi) MIN.
 - ALL CONC. SHALL BE CONSOLIDATED BY MECH. VIBRATION
 - WALL SHALL NOT BE BACKFILLED HIGHER THAN 3'-6" ABOVE THE TOP OF FOOTING BEFORE THE CONCRETE SLAB-ON-GRADE & THE STRUCTURAL FLOOR IS COMPLETED.
 - MINIMUM REINFORCEMENT LAP LENGTH = 24".

FOUNDATION DETAILS MINIMUM REQUIREMENTS ONE AND TWO STORY RESIDENTIAL	
LA PLATA COUNTY COLORADO BUILDING DEPARTMENT	STANDARD NO. 101
APPROVED: B. KNOWLTON DATE: JUNE 2004	SCALE: 1/2" = 1'-0"
DRAWN BY: CW	