



EXAMPLE:
SEE
GENERAL
NOTES.

1
102 9'-0" CONCRETE BASEMENT
WALL DETAIL

- NOTES:**
- CONC. STRENGTH = 3000psi MIN. @ 28 DAYS
 - REINFORCEMENT = GR 40 (fy=40,000 psi) MIN.
 - ALL CONC. SHALL BE CONSOLIDATED BY MECH. VIBRATION
 - WALL SHALL NOT BE BACKFILLED HIGHER THAN 3'-6" ABOVE THE TOP OF FOOTING BEFORE THE CONCRETE SLAB-ON-GRADE & THE STRUCTURAL FLOOR IS COMPLETED.
 - MINIMUM REINFORCEMENT LAP LENGTH = 24"

FOUNDATION DETAILS MINIMUM REQUIREMENTS ONE AND TWO STORY RESIDENTIAL	
LA PLATA COUNTY COLORADO BUILDING DEPARTMENT	STANDARD NO. <div style="text-align: center; font-size: 2em;">1</div> <div style="text-align: center; font-size: 2em;">102</div>
APPROVED: B. KNOWLTON DATE: JUNE 2004	
DRAWN BY: CW	SCALE: 1/2" = 1'-0"