



1
106

MONOLITHIC CONC. STEMWALL

NOTES:

- CONC. STRENGTH = 3000psi MIN. @ 28 DAYS.
- REINFORCEMENT = GR 40 ($f_y=40,000$ psi) MIN.
- ALL CONC. SHALL BE CONSOLIDATED BY MECH. VIBRATION.
- MINIMUM REINFORCEMENT LAP LENGTH = 24".
- COMPACT ALL BACKFILL TO 95% OF ASTM D-698.
- ALL FDNS. SHALL BEAR ON DENSE UNDISTURBED NATIVE SOIL.
- REINFORCEMENT SHALL BE CONTINUOUS AROUND ALL CORNERS.

FOUNDATION DETAILS
MINIMUM REQUIREMENTS
ONE AND TWO STORY RESIDENTIAL

LA PLATA COUNTY COLORADO
BUILDING DEPARTMENT

STANDARD NO.

APPROVED: B. KNOWLTON DATE: JUNE 2004

106

DRAWN BY: CW

SCALE: 3/4" = 1'-0"